

Attachment (4) PPI Response-Amend 0004

NO	Reference	Question	Government Response
1	SF1449, Page 18	Is there any forms for the bidder's previous experience? Is it possible to pick up one experience from cleaning, painting, or architecture? Or is it possible to submit several different experiences all put together?	No, bidders shall use their own format. Bidders shall decide the number and type of project as a past experience.
2	ELIN A001AA	Des the emergency response include the cost of parts or is it possible to charge separately?	See PWS Item 3.1 and 3.1.1 of Sub-annex 1502000. The price shall include the cost of parts. Liability limit is ¥40,000 or 40 labor hours. When the cost of service order work exceeds the liability limit, the Government may issue Non-recurring work orders for the amount exceeding the liability limit.
3	Atch J-1502000-8	It seems that there are many discontinued products, but is there the latest warranty?	No. When the products are no longer available at the market, provide the products that are equivalent or better quality than the existing ones.
4	ELIN A705AF	Is floor stripping necessary if the floor is very dirty? If yes, is it charged separately by ELIN A705AF?	Yes. Old wax shall be stripped off with no additional cost to the Government. Do not wax on the dirty surface. See PWS Spec Item 4.2.2 of Sub-annex 1503010.
5	ELIN A701AA through A701AC	Is rewaxing necessary all of the room? If yes, is rewaxing including in COM work (ELIN A701AA through A701AC) or in cleaning work (ELIN A705AA through A705AD)?	Yes. Floor stripping and rewaxing shall be performed to all the resilient floors. Rewaxing is included in ELIN X705AA through X705AD Whole Unit Cleaning. Partial rewaxing will be order by ELIN X705AF Floor Stripping and Rewaxing. See PWS Spec Item 4.1 and 4.2.2 of Sub-annex 1503010.
6	SF1449, Page 19	Refrigerant freon handling technician is included refrigerant recovery technician now. Is it possible to submit only refrigerant freon handling technician's qualification?	Yes. Per PWS Spec Item 2.2.1 of Sub-annex 1502000, personnel shall have either Refrigerant Freon Handling Technician <u>or</u> Refrigerant Recovery Technician for refrigerant recovery work.
7	ELIN A001AA	Is there a maximum amount for ELIN item A001AA?	Yes. Number of service order is limited to 200 orders during one-year performance period. See PWS Spec Item 3.1 of Sub-annex 1502000.
8	ELIN A706AA and A706AB	When does ELIN items A706AA and A706AB apply?	ELIN 706 Unit Priced Labor (UPL) Work is utilized to accomplish a task not required by the priced ELIN 001 and 701 through 705. See PWS Spec Item 2.15.2 of Annex 2.